

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



2 of 2

Violations Comments

Violation #5. Maintenance & Repair
Observed burnt out light bulbs in classroom 401 (41fc), 201 (40fc), and 204 (41fc). Replace light bulbs.
CODE REFERENCE: 5. Maintenance and Repair. 5(1)(e)8.h SREF. Light fixtures and window surfaces, both inside and outside, shall be kept clean, serviceable, and in good repair at all times. 5(1)(e)8.i. Custodial areas shall be kept clean, safe, and orderly at all times. Custodial equipment shall be in good repair at all times. 5(1)(e)8.j SREF. Building components & finishes shall be kept clean & in good repair.

Inspection Conducted By: Javon Johnakin (27326)
Inspector Contact Number: Work: (305) 623-3500 ex.
Print Client Name:
Date: 10/24/2023

Inspector Signature:

A handwritten signature in blue ink, appearing to be "Javon Johnakin".

Client Signature:

Send by email